



9 Isaac Street  
Norwalk, CT  
06850  
Phone: 203-853-9792  
Fax: 203-853-0273  
www.brooksenviro.com

March 7, 2017

Gino Faiella, *Director of Facilities*  
Newtown Public Schools  
Maintenance Department  
12 Berkshire Road  
Sandy Hook, CT 06482-1398

Dear Mr. Faiella:

The results of recent radon-in-air testing at **Newtown High School** are enclosed. You will find one page presented in a format suitable for posting. The radon-in-air concentration is given in the second column labeled "pCi/L" and the location is given in the third column labeled "Room". Note that the symbol "<" indicates no radon was detected. In that case, the number given (0.3) represents the detection limit.

This round of testing was done in response to the five-year reevaluation protocol contained in guidelines issued by the Connecticut Department of Public Health (CT-DPH) for Connecticut Public Act 03-220, "An Act Concerning Indoor Air Quality in Schools". Charcoal samplers, manufactured and analyzed by Air-Chek Inc., 1936 Butler Bridge Road, Mills River, NC 28759, were placed in 10% of the rooms tested during the initial round of testing in 2007. Testing took place during a school week with building systems operating normally. Teachers were instructed to keep windows closed during the testing.

The Connecticut guideline for radon-in-air is 4 pCi/L. The Department of Public Health currently feels that no further action is indicated when results this low are obtained. Although exposures in this range do present some risk of lung cancer, no remedial measures are recommended since reduction of levels this low may be impossible to achieve.

**All of the results obtained in this survey were below 4 pCi/L.**

Sincerely yours,

A handwritten signature in blue ink that reads "Mark F. Granville". The signature is written in a cursive, flowing style.

Mark F. Granville  
*Senior Consultant*

enclosures  
MG170014

## APPENDIX

Some of the samples listed with the results were collected as part of quality control. These samples fall into two categories: (1) blanks and (2) duplicates.

The blank sample yielded <0.3, indicating this batch of packets was not contaminated and the laboratory did not introduce an upward bias. The blanks are indicated by "BL" following a room designation.

Duplicates were collected by setting two packets 4" apart in one room. The results indicate an overall standard deviation of measurement of less than 0.25 pCi/L.

| Duplicate   | #1  | #2   | Mean | StdDev | RPD |
|-------------|-----|------|------|--------|-----|
| main office | 0.5 | <0.3 | <0.4 | <0.25  | NA  |

The CT-DPH states that the quality of the results should be questioned if the relative percent difference (RPD) of results over 4.0 pCi/l is 25% or more. Since all of the results for duplicates are less than 4.0 pCi/L, the CT criteria is not applicable. The National Radon Safety Board states that RPD less than 37% is acceptable for results greater than 4 pCi/L and RPD less than 67% is acceptable for results less than 4 pCi/L (excluding non-detects). Since one of the duplicate pair is non-detect, the NRSB criteria is not applicable.

**NEWTOWN PUBLIC SCHOOLS / HIGH SCHOOL**

| <b>Kit #</b> | <b>pCi/L</b> | <b>Room</b> | <b>Hours</b> | <b>Started</b>       | <b>Ended</b>         | <b>Analyzed</b> | <b>NOTES</b> | <b>MST %</b> |
|--------------|--------------|-------------|--------------|----------------------|----------------------|-----------------|--------------|--------------|
| 7867739      | < 0.3        | A002        | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 3.7%         |
| 7867734      | < 0.3        | B136        | 72           | 2017-02-28 @ 1:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 4.4%         |
| 7867735      | < 0.3        | B136 BL     | 72           | 2017-02-28 @ 1:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 2.9%         |
| 7867732      | 0.5          | B143        | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 4.5%         |
| 7867731      | < 0.3        | B146        | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 4.5%         |
| 7867737      | < 0.3        | C081        | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 3.7%         |
| 7867733      | < 0.3        | CAREER      | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 3.7%         |
| 7867738      | 0.7          | D099        | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 4.5%         |
| 7867736      | < 0.3        | F001        | 71           | 2017-02-28 @ 2:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 2.9%         |
| 7867740      | 0.5          | MAIN OFFICE | 72           | 2017-02-28 @ 1:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 4.5%         |
| 7867741      | < 0.3        | MAIN OFFICE | 72           | 2017-02-28 @ 1:00 pm | 2017-03-03 @ 1:00 pm | 2017-03-06      |              | 4.5%         |